

सत्यव्रत साहु, आई.ए.एस.
संयुक्त सचिव
Satyabrata Sahu, I.A.S.
Joint Secretary



भारत सरकार
पेयजल एवं स्वच्छता मंत्रालय
Government of India
Ministry of Drinking Water and Sanitation
B-2 Wing, 4th Floor, Paryavaran Bhawan,
CGO Complex, Lodhi Road, New Delhi-110003
Tel. : 24361043 Fax : 24364113
E-mail : jstm@nic.in
Website : www.ddws.nic.in

DO No. WQ-11021/47/2015/WQ

Dated: 06th Nov. 2015

Dear Madam/Sir

Hon'ble Minister of Women and Child Development has desired to factually know the status of drinking water quality in Anganwadi Centres across the States. In this context, a meeting was held in the office of Addl. Secretary, Ministry of Women and Child Development on 12th Oct 2015.

2. In above context, you are requested to direct the concerned officers to analyze at least 10 samples each in case for Sikkim, Meghalaya, Nagaland, Tripura, Mizoram, Goa, Puducherry, Lakshadweep, Dadra & Nagar Haveli, Daman & Diu, Andaman & Nicobar islands and Chandigarh 25 samples each, for other States for general physico-chemical and bacteriological parameters. The Ministry of Women & Child Development has provided a list of selected high burdened districts for 10 States- Bihar, Chhattisgarh, Jharkhand, Madhya Pradesh, Odisha, Rajasthan, Uttar Pradesh and Uttarakhand, which has been attached herewith. States should get drinking water quality testing done for the districts mentioned in the list. Those States, name of which are not in high burdened districts provided by the Ministry of Women & Child Development, may select high burdened districts associated with drinking water quality, JE/AES problem or districts having significant cases of undernutrition/Anaemia for children in rural areas. The signed Report should be sent within a week to this Ministry by post as well as to the email-id of Shri D. Rajasekhar, Dy Advisor (WQ) at sharathraj2008@gmail.com and to Dr. Brajesh Shrivastava, Consultant (Water Quality) at brajeshkr.s@gov.in. The Report should contain analysis value for parameters mentioned below in following format:

S. No.	Characteristic	Unit	BIS specified maximum Permissible Limit in the absence of alternate source	Analysis Result
1	Total Dissolved Solids (TDS)	Milligram/ litre	2000	

ग्रामीण क्षेत्रों में
पेयजल स्थायित्व एवं सम्पूर्ण स्वच्छता

Sustainable Drinking Water and
Sanitation for all in Rural Areas


एक कदम स्वच्छता की ओर / Sanitation is Next to Godliness

2	Colour	Hazen unit	15	
3	Turbidity	NTU	5	
4	Total Hardness	Milligram/litre	600	
5	Ammonia	Milligram/litre	0.5	
6	Free Residual Chlorine	Milligram/litre	1.0	
7	pH	--	6.5-8.5	
8	Chloride	Milligram/litre	1000	
9	Fluoride	Milligram/litre	1.5	
10	Arsenic	Milligram/litre	0.05	
11	Iron	Milligram/litre	0.3	
12	Nitrate	Milligram/litre	45	
13	Sulphate	Milligram/litre	400	
14	E-Coli or Thermotolerant coliforms	Number/100ml	NIL	

3. Timely submission of the Report to this Ministry would be appreciated. The Report, after consolidation in this Ministry, would be sent to the Ministry of Women & Child Development.

With regards,

Yours sincerely,


 6/11/15
 [Satyabrata Sahu]

To,

Principal Secretary/Secretary-in-charge of Rural Drinking Water in all the States/UTs

SELECTED 200 HIGH - BURDEN DISTRICTS

A. COMMON DISTRICTS SELECTED ON THE COUNT OF UN... AND ANAEMIA USING DLHS-II DATA AS WELL AS FROM EAG STATES											
Sl. No.	State	Districts	No. of Blocks	Sl. No.	State	Districts	No. of Blocks	Sl. No.	State	Districts	No. of Blocks
1	Bihar	Bhagahpur	16	51	Madhya Pradesh	Raisen	7	101	Uttar Pradesh	Chitrakoot	5
2		Buxar	11	52		Rajgarh	6	102		Etawah	8
3		Darbhanga	18	53		Ratlam	6	103		Faizabad	11
4		Gopalganj	14	54		Shajapur	8	104		Farukhabad	7
5		Jamul	10	55		Sheopur	3	105		Fatehpur	13
6		Jehanabad	7	56		Shivpuri	8	106		Ghaziabad	8
7		Lakhisarai	7	57		Sidhi	8	107		Ghazipur	16
8		Madhepura	13	58		Tikamgarh	6	108		Hamirpur	7
9		Madhubani	21	59		Ujjain	6	109		Hardol	19
10		Munger	9	60		Umaria	3	110		Hathras/Mahamaya Nagar	7
11		Muzaffarpur	15	61		Vidisha	7	111		Jhansi	8
12		East Champarah	27	62		Khargone (West Nimar)	9	112		Kanpur Nagar	10
13		Purnja	14	63	Orissa	Boudh (Bauda)	3	113		Kaushambi	8
14		Saharsa	10	64		Dhenkanal	8	114		Sant Kabir Nagar	7
15		Samastipur	20	65		Gajapati	7	115		Lucknow	8
16		Sitamarhi	17	66		Kalahandi	13	116		Mahoba	4
17		Supaul	11	67		Koraput	14	117		Mainpuri	9
18	Chhattisgarh	Bastar	14	68		Malkangiri	7	118		Maunathbhanjan	9
19		Dantewada	11	69	Rajasthan	Ajmar	8	119		Meerut	12
20		Durg	22	70		Alwar	14	120		Moradabad	13
21		Jashpur	8	71		Baran	7	121		Muzaffarnagar	14
22		Kanker	7	72		Barmer	8	122		Siddharth Nagar	14
23		Kawardha	5	73		Bikaner	6	123		Jaloon	9
24		Korba	5	74		Chittorgarh	14	124		Kushinagar	14
25		Mahasamund	5	75		Churu	6	125		Pilibhit	7
26		Rajpur	15	76		Dausa	5	126		Rae Bareli	21
27	Jharkhand	Chatra	10	77		Dholpur	4	127		Rampur	6
28		Dhanbad	8	78		Dungarpur	5	128		Shahjahanpur	15
29		Dumka	4	79		Jaipur	13	129		Unnao	16
30		Giridih	12	80		Jhunjhunun	8	130	Uttaranchal	Chamoli	9
31		Koderma	5	81		Jodhpur	10	131		Champawat	4
32		West Singhbhm	15	82		Karauli	5	132		Haridwar	6
33	Madhya Pradesh	Barwani	7	83		Kota	5	133		Pauri Garhwal	15
34		Bhind	6	84		Rajsamand	7	134		Tehri Garhwal	10
35		Chhindwara	11	85		Sawai Madhopur		135		Udham Singh Nagar	6
36		Damoh	7	86		Sirohi	5			Total (No. of Block)	355
37		Datia	3	87		Tonk	7				
38		Dewas	6	88		Udaipur	11				
39		Dindori	7	89	Uttar Pradesh	Kanpur Dehat	10				
40		Khandwa (East Nimar)	7	90		Allgarh	12				
41		Guna	5	91		Allahabad	28				
42		Hoshangbad	7	92		JP Nagar	6				
43		Indore	4	93		Auraiya					
44		Jabalpur	6	94		Azamgarh	22				
45		Jhabua	6	95		Baghpat	6				
46		Katnl	6	96		Banda	8				
47		Mandsaur	5	97		Barabaki	17				
48		Morena	7	98		Sant Ravidas Nagar	6				
49		Neemuch		99		Bulandshahr	15				
50		Panna	5	100		Chandaull	9				
Total (No. of Blocks)			482	Total (No. of Blocks)			416	Grand Total (No. of Blocks)			1253